

# Energy performance certificate (EPC)

Duxford House  
Heathwood Road  
Higher Heath  
WHITCHURCH  
SY13 2HG

Energy rating

**B**

Valid until: **27 February 2030**

Certificate number: **0963-3898-7328-2420-6025**

## Property type

Detached house

## Total floor area

123 square metres

## Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy rating and score

This property's current energy rating is B. It has the potential to be A.

[See how to improve this property's energy efficiency.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

## Breakdown of property's energy performance

## Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Walls	Average thermal transmittance 0.19 W/m <sup>2</sup> K	Very good
Roof	Average thermal transmittance 0.09 W/m <sup>2</sup> K	Very good
Floor	Average thermal transmittance 0.15 W/m <sup>2</sup> K	Very good
Windows	High performance glazing	Very good
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Average

Feature	Description	Rating
Lighting	Low energy lighting in all fixed outlets	Very good
Air tightness	Air permeability 3.9 m <sup>3</sup> /h.m <sup>2</sup> (as tested)	Good
Secondary heating	None	N/A

## Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO<sub>2</sub>. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Solar photovoltaics

## Primary energy use

The primary energy use for this property per year is 41 kilowatt hours per square metre (kWh/m<sup>2</sup>).

▶ [About primary energy use](#)

### How this affects your energy bills

An average household would need to spend **£458 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £39 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2020** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Heating this property

Estimated energy needed in this property is:

- 4,659 kWh per year for heating
- 2,200 kWh per year for hot water

### Impact on the environment

This property's current environmental impact rating is B. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

## Carbon emissions

### An average household produces

6 tonnes of CO<sub>2</sub>

### This property produces

1.7 tonnes of CO2

---

**This property's potential production**

1.4 tonnes of CO2

---

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

► [Do I need to follow these steps in order?](#)

---

## Step 1: Solar water heating

Typical installation cost

£4,000 - £6,000

---

Typical yearly saving

£39

---

Potential rating after completing step 1

92 A

---

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

[Find ways to save energy in your home.](#)

Who to contact about this certificate

## Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

**Assessor's name**

Julie Lock

---

**Telephone**

07990 088026

---

**Email**

[julie.lock@shropshire.gov.uk](mailto:julie.lock@shropshire.gov.uk)

---

## Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.